

Karnataka Fire & Emergency Services

Office of the District Fire Officer Yelahanka Fire Station, Nitte Minakshi College Road, Vadeyarapura, Bagaluru Cross, Yelahanka, Bengaluru-64



No.34/DFO/YLFS/2023

Date:23/12/2023

To, Secretary, M/s. Kesar The International School, Hosahalli Village, Vidyanagar Road, Bengaluru North - 562157.

Sub: Issue of "Fire safety compliance report" with respect to fire prevention, firefighting and evacuation measures maintained/required at "Kesar – The International School, Hosahalli Village, Vidyanagar Road, Bengaluru North - 562157."

Ref: 1) CN:34/FSR/DFO/YELAHANKA/2023 dated: 23/12/2023

2) Your request letter dated 8/12/2023.

With reference to the subject cited (1) above, a conditional Fire Compliance Report was issued for "KESAR - THE INTERNATIONAL SCHOOL", Situated at Sy.No.6/5 & 6/6, Hosahalli Village, Vidyanagar Road, Bengaluru North – 562157

In your letter in reference (2) above, requested to Renewal of "Compliance report" In this regard the building was inspected by District Fire Officer, Yelahanka Fire Station Fire Station on 23-12-2023 and submitted the report & Recommended for Renewal of Compliance Certificate.

Under the above circumstance the Kamataka Fire & Emergency Services Department is Renewing the Compliance Certificate of "KESAR - THE INTERNATIONAL SCHOOL", building constructed at Sy.No.6/5 & 6/6, Hosahalli Village, Vidyanagar Road, Bengaluru North – 562157.

ASTRICT FIRE UFFICER
Violiana Fine STATION

MANUALORE

Subject to proper maintenance of firefighting systems in good working condition, providing of one standby generator and to impart training for 40% of employees/staff in basic fire fighting at R.A Mundkur Fire & Emergency Services Academy, Bangalore within 90 days from the date of issue of this report.

"This Clearance report is valid for one year from the date of issue and is renewable without fail'.

Yours's Faithfully

MALT FIRE OFFICER

BANGALORE